

Outlet Code	Location/Description	Results	Above AL?	School	Grades
WF-AD01	WATER FOUNTAIN IN HALL	1.45	No	Admin Building	N/A
S-AD02	MENS BATHROOM SINK	3.1	No	Admin Building	N/A
S-AD03	WOMENS BATHROOM SINK	ND	No	Admin Building	N/A
S-AD04	SINK IN KITCHEN	ND	No	Admin Building	N/A