

Outlet Code	Location/Description	Results	Above AL?	School	Grades
S-FR01	SINK IN KITCHEN	1.85	No	Frost Elementary School	K-5
S-FR02	SINK IN KITCHEN	3.52	No	Frost Elementary School	K-5
S-FR03	SINK IN KITCHEN	12.1	No	Frost Elementary School	K-5
IO-FR04	OUTLET IN KITCHEN	4.87	No	Frost Elementary School	K-5
S-FR05	BATHROOM SINK IN BOILER ROOM	9.01	No	Frost Elementary School	K-5
S-FR06	GIRL BATHROOM SINK	1.36	No	Frost Elementary School	K-5
S-FR07	BOYS BATHROOM SINK	1.26	No	Frost Elementary School	K-5
WF-FR08	WATER FOUNTAIN IN HALL	3.33	No	Frost Elementary School	K-5
WF-FR09	WATER FOUNTAIN IN HALL	ND	No	Frost Elementary School	K-5
WF-FR10	WATER FOUNTAIN IN HALL	1.42	No	Frost Elementary School	K-5
WF-FR11	WATER FOUNTAIN IN HALL	1.45	No	Frost Elementary School	K-5
WF-FR12	WATER FOUNTAIN IN HALL	ND	No	Frost Elementary School	K-5
WF-FR13	WATER FOUNTAIN IN HALL	ND	No	Frost Elementary School	K-5
S-FR14	GIRL BATHROOM SINK	3	No	Frost Elementary School	K-5
S-FR15	BOY BATHROOM SINK	1.92	No	Frost Elementary School	K-5
B-FR16	BUBBLER IN ROOM 5	19.30	Yes	Frost Elementary School	K-5
B-FR17	BUBBLER IN ROOM 2	20.7	Yes	Frost Elementary School	K-5
B-FR18	BUBBLER IN ROOM 4	ND	No	Frost Elementary School	K-5
B-FR19	BUBBLER IN ROOM 7	8.85	No	Frost Elementary School	K-5
S-FR20	SINK BETWEEN ROOM 6 & ROOM 8	1.78	No	Frost Elementary School	K-5
S-FR21	SINK BETWEEN ROOM 9 & ROOM 11	1.48	No	Frost Elementary School	K-5
WF-FR22	WATER FOUNTAIN IN HALL	6.47	No	Frost Elementary School	K-5
WF-FR23	WATER FOUNTAIN IN HALL	15.8	Yes	Frost Elementary School	K-5
WF-FR24	WATER FOUNTAIN IN HALL	1.82	No	Frost Elementary School	K-5
WF-FR25	WATER FOUNTAIN IN HALL	1.33	No	Frost Elementary School	K-5
S-FR26	FACULTY BATHROOM SINK	4.15	No	Frost Elementary School	K-5
S-FR27	FACULTY BATHROOM SINK	1.6	No	Frost Elementary School	K-5
S-FR28	SINK IN FACULTY ROOM	ND	No	Frost Elementary School	K-5
S-FR29	SINK IN NURSE	ND	No	Frost Elementary School	K-5
S-FR30	BATHROOM SINK IN NURSE	1.12	No	Frost Elementary School	K-5
WF-FR31	WATER FOUNTAIN IN HALL	ND	No	Frost Elementary School	K-5
WF-FR32	WATER FOUNTAIN IN HALL	ND	No	Frost Elementary School	K-5
S-FR33	FACULTY BATHROOM SINK IN MAIN OFFICE	ND	No	Frost Elementary School	K-5
S-FR34	SINK IN MAIN OFFICE	ND	No	Frost Elementary School	K-5
WF-FR35	WF IN MULTI PURP ROOM	4.88	No	Frost Elementary School	K-5