



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109**

6/13/2022

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/26/2022. The results are tabulated on the attached data pages for the following client designated project:

East Brunswick SD - Irwin Elementary School / Project #: PR-210315-1662

The reference number for these samples is EMSL Order #012208534. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208534

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/26/2022 01:15 PM

Project: East Brunswick SD - Irwin Elementary School / Project #: PR-210315-1662

Analytical Results

Client Sample Description 39-0522-I01 Bathroom Sink in Nurse
Collected: 5/22/2022 11:19:00 AM
Lab ID: 012208534-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	13.7	1.00 µg/L	6/8/2022 VD	6/8/2022 19:35 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description 39-0522-I02 Sink in Faculty Lounge
Collected: 5/22/2022
Lab ID: 012208534-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/8/2022 VD	6/8/2022 19:36 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description 39-0522-I03 Kitchen - Wash Sink - Left
Collected: 5/22/2022
Lab ID: 012208534-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	10.2	1.00 µg/L	6/8/2022 EM	6/9/2022 19:27 JW
-------	------	------	-----------	-------------	-------------------

Client Sample Description 39-0522-I04 Kitchen - Middle Pot Filler
Collected: 5/22/2022
Lab ID: 012208534-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/8/2022 VD	6/8/2022 19:41 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description 39-0522-I05 Kitchen - Wash Sink - Right
Collected: 5/22/2022
Lab ID: 012208534-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/8/2022 VD	6/8/2022 19:43 VD
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208534
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/26/2022 01:15 PM

Project: **East Brunswick SD - Irwin Elementary School / Project #: PR-210315-1662**

Analytical Results

Client Sample Description 39-0522-106 **Collected:** 5/22/2022 **Lab ID:** 012208534-0006
 WF in Hall

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/8/2022 VD	6/8/2022 19:44 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description 39-0522-107 **Collected:** 5/22/2022 **Lab ID:** 012208534-0007
 Kitchen - Prep Sink

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/8/2022 VD	6/8/2022 19:49 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description 39-0522-108 **Collected:** 5/22/2022 **Lab ID:** 012208534-0008
 Deionized Blank

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/8/2022 VD	6/8/2022 19:50 VD
-------	------	----	-----------	-------------	-------------------

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results