



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

6/10/2022

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/26/2022. The results are tabulated on the attached data pages for the following client designated project:

East Brunswick SD - Memorial Elementary School / Project #: PR-210315-1662

The reference number for these samples is EMSL Order #012208532. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208532

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/26/2022 01:15 PM

Project: East Brunswick SD - Memorial Elementary School / Project #: PR-210315-1662

Analytical Results

Client Sample Description 39-0522-M01
 Sink in Served Kitchen 110H
Collected: 5/22/2022 5:30:00 AM
Lab ID: 012208532-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/7/2022 VD	6/8/2022 07:11 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description 39-0522-M02
 Sink in Kitchen 110D
Collected: 5/22/2022 5:31:00 AM
Lab ID: 012208532-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.68	1.00 µg/L	6/7/2022 VD	6/8/2022 07:15 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description 39-0522-M03
 Sink in Kitchen 110D
Collected: 5/22/2022 5:32:00 AM
Lab ID: 012208532-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	1.14	1.00 µg/L	6/7/2022 VD	6/8/2022 07:17 VD
-------	------	------	-----------	-------------	-------------------

Client Sample Description 39-0522-M04
 Chiller Bottle Filler in Cafetorium 110 (Filler)
Collected: 5/22/2022 5:33:00 AM
Lab ID: 012208532-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/7/2022 VD	6/8/2022 07:21 VD
-------	------	----	-----------	-------------	-------------------

Client Sample Description 39-0522-M05
 Sink in Faculty Work Room 106
Collected: 5/22/2022 5:34:00 AM
Lab ID: 012208532-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
--------	-----------	--------	----------	---------------------	-------------------------

METALS

200.8	Lead	ND	1.00 µg/L	6/7/2022 VD	6/8/2022 07:23 VD
-------	------	----	-----------	-------------	-------------------

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012208532

CustomerID: EDI50

CustomerPO:

ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/26/2022 01:15 PM

Project: East Brunswick SD - Memorial Elementary School / Project #: PR-210315-1662

Analytical Results

Client Sample Description 39-0522-M06
 Sink in Main Office Mail Area
Collected: 5/22/2022
 5:35:00 AM
Lab ID: 012208532-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/7/2022 VD	6/8/2022 07:24 VD

Client Sample Description 39-0522-M07
 Sink in Nurse Room 103
Collected: 5/22/2022
 5:36:00 AM
Lab ID: 012208532-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/7/2022 VD	6/8/2022 07:26 VD

Client Sample Description 39-0522-M08
 Deionized Blank
Collected: 5/22/2022
 5:37:00 AM
Lab ID: 012208532-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/7/2022 VD	6/8/2022 07:28 VD

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results