



Environmental Design Inc.

Professional Environmental Consultants

Lead (Pb) in Water Sampling Chain of Custody

EMSL Order ID (Lab Use Only):

Company:	Environmental Design Inc. (EDI-50)	EMSL Bill To:	EDI-50
Street:	5434 King Avenue, Suite 101	Phone:	856-616-9516
City/State/Zip:	Pennsauken, NJ 08109	Fax:	856-616-9519
Send Report To:	Tom Pruno	Send Results To:	tp@editesting.com/ mh@editesting.com
State Samples Taken:	NJ	Turnaround Time (TAT):	2 Weeks

Matrix	Method	Instrument	Reporting Limit	Preservative
Drinking Water (Preserved w/HNO ₃ pH <2)	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	Nitric acid
EDI Client/Site:	East Brunswick SD – Warnsdorfer Elementary School		EDI Project #:	PR-210315-1662
Special Instructions: ** Please provide Excel Data File as well as Standard Report **				
Email Results to: tp@editesting.com/ mh@editesting.com				

Sample #	Sample Description/Location	Volume	Date/Time Sampled
44-0522-W01	Kitchen - Food prep sink (left)	250 mL	5/22/2022 10:00 AM
44-0522-W02	Kitchen - Food prep sink (right)	250 mL	5/22/2022 10:01 AM
44-0522-W03	Kitchen - Dishwasher sink (right)	250 mL	5/22/2022 10:02 AM
44-0522-W04	Kitchen - Dishwasher sink (left)	250 mL	5/22/2022 10:03 AM
44-0522-W05	Nurse's Office sink	250 mL	5/22/2022 10:07 AM
44-0522-W06	Principal's Office sink	250 mL	5/22/2022 10:11 AM
44-0522-W07	WF/ Filler station - Hallway across from Nurse's Office (filler)	250 mL	5/22/2022 10:12 AM
44-0522-W08	Faculty Room sink	250 mL	5/22/2022 10:14 AM
44-0522-W09	WF/ Filler station - Outside of restrooms at corner of Grade 5 and Kindergarten (filler)	250 mL	5/22/2022 10:17 AM
44-0522-W10	Deionized Blank	250 mL	

Relinquished By:		Received By:	
Date: 5/23/22	Time:	Date:	Time:
Sampler: Melanie Hughes		Total Samples:	Page: 1 of 1



EDI is a Service Disabled Veteran Owned Small Business!



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Tom Pruno
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109**

6/3/2022

Phone: (856) 616-9516

Fax: (586) 616-9517

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 5/23/2022. The results are tabulated on the attached data pages for the following client designated project:

East Brunswick SD-Warnsdorfer Elementary School

The reference number for these samples is EMSL Order #012208100. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208100
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/23/2022 12:55 PM

Project: **East Brunswick SD-Warnsdorfer Elementary School**

Analytical Results

Client Sample Description 44-0522-W01
 Kitchen-Food prep sink (left) **Collected:** 5/22/2022 10:00:00 AM **Lab ID:** 012208100-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.33	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:20

Client Sample Description 44-0522-W02
 Kitchen-Food prep sink (right) **Collected:** 5/22/2022 10:01:00 AM **Lab ID:** 012208100-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.0	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:24

Client Sample Description 44-0522-W03
 Kitchen-Dishwasher sink (right) **Collected:** 5/22/2022 10:02:00 AM **Lab ID:** 012208100-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.43	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:26

Client Sample Description 44-0522-W04
 Kitchen-Dishwasher sink (left) **Collected:** 5/22/2022 10:03:00 AM **Lab ID:** 012208100-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.16	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:27

Client Sample Description 44-0522-W05
 Nurse's Office sink **Collected:** 5/22/2022 10:07:00 AM **Lab ID:** 012208100-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.91	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:29

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012208100
 CustomerID: EDI50
 CustomerPO:
 ProjectID:

Attn: **Tom Pruno**
Environmental Design, Inc.
5434 King Avenue
Suite 101
Pennsauken, NJ 08109

Phone: (856) 616-9516
 Fax: (586) 616-9517
 Received: 5/23/2022 12:55 PM

Project: **East Brunswick SD-Warnsdorfer Elementary School**

Analytical Results

Client Sample Description 44-0522-W06
 Principal's Office sink
Collected: 5/22/2022 10:11:00 AM
Lab ID: 012208100-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.18	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:30

Client Sample Description 44-0522-W07
 WF/Filler station-Hallway across from Nurse's office (filler)
Collected: 5/22/2022 10:12:00 AM
Lab ID: 012208100-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:32

Client Sample Description 44-0522-W08
 Faculty room sink
Collected: 5/22/2022 10:14:00 AM
Lab ID: 012208100-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.00	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:34

Client Sample Description 44-0522-W09
 WF/Filler station-Outside of restrooms at corner of Grade 5 and Kindergarten (filler)
Collected: 5/22/2022 10:17:00 AM
Lab ID: 012208100-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:38

Client Sample Description 44-0522-W10
 Deionized Blank
Collected: 5/22/2022
Lab ID: 012208100-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	6/1/2022 KG	5/31/2022 KG 17:40



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012208100
CustomerID:	EDI50
CustomerPO:	
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results